


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Plugs, socket-outlets and couplers for industrial purposes
Name and address of the applicant	LEGRAND FRANCE 6, Paul Nouel, 76770 MALAUNAY - France
Name and address of the manufacturer	LEGRAND FRANCE 6, Paul Nouel, 76770 MALAUNAY - France
Name and address of the factory	<input checked="" type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See Annex
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	CTF2
Model / Type Ref.	Model: Hypra 63A References: see annex
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR 3333/60011202-504983E dated 2003-12-22: Update further to the evolution of the standard(s) <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012 IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	60011202-503723E, 60011202-503723E/1, 60011202-503723E/2, 135754-672674

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 24/04/2017

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX

Name and address of the factories:
LEGRAND FRANCE

Route de Tendos ; 76690 FONTAINE LE BOURG - France

LEGRAND FRANCE

(Division Industrie, ZI des Coutures, 519 rue Jules Ferry ; 02120 GUISE - France


REFERENCES, MAIN CHARACTERISTICS

Bended plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Metallic	0 536 72	
63 A	3P+E	380/415 V~	50/60 Hz	6h	Rubber	0 538 63	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Rubber	0 538 64	
63 A	3P+E	380/415 V~	50/60 Hz	6h	Metallic	0 538 73	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Metallic	0 538 74	

Connector						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Plastic	0 536 82	0 593 86
63 A	3P+E	200/250 V~	50/60 Hz	9h	Plastic	0 536 83	0 593 87
63 A	2P+E	200/250 V~	50/60 Hz	6h	Rubber	0 536 92	
63 A	3P+E	380/415 V~	50/60 Hz	6h	Plastic	0 538 83	0 594 87
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Plastic	0 538 84	0 594 88
63 A	3P+E	380/415 V~	50/60 Hz	6h	Rubber	0 538 93	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Rubber	0 538 94	



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 24/04/2017

 Signature: **Jean-François BRUEL**
 Certification Officer


ANNEX (continued)

Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Plastic	0 536 22	0 593 26
63 A	3P+E	200/250 V~	50/60 Hz	9h	Plastic	0 536 23	0 593 27
63 A	3P+E	380/415 V~	50/60 Hz	6h	Plastic	0 538 23	0 594 27
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Plastic	0 538 24	0 594 28
63 A	3P+E	380/415 V~	50/60 Hz	6h	Metallic	0 538 33	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Metallic	0 538 34	
63 A	3P+E	480/500 V~	50/60 Hz	7h	Plastic		0 594 29

Straight Plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Plastic	0 536 42	0 593 46
63 A	3P+E	200/250 V~	50/60 Hz	9h	Plastic	0 536 43	0 593 47
63 A	2P+E	200/250 V~	50/60 Hz	6h	Rubber	0 536 52	
63 A	3P+E	380/415 V~	50/60 Hz	6h	Plastic	0 538 43	0 594 47
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Plastic	0 538 44	0 594 48
63 A	3P+E	380/415 V~	50/60 Hz	6h	Rubber	0 538 53	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Rubber	0 538 54	
63 A	3P+E	480/500 V~	50/60 Hz	7h	Plastic		0 594 49



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 24/04/2017

Signature: **Jean-François BRUEL**
 Certification Officer

ANNEX(end)


Unit surface type socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Plastic	0 537 22	0 593 36
63 A	3P+E	200/250 V~	50/60 Hz	9h	Plastic		0 593 37
63 A	3P+E	380/415 V~	50/60 Hz	6h	Plastic	0 537 23	0 594 37
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Plastic	0 537 24	0 594 38
63 A	3P+E	380/415 V~	50/60 Hz	6h	Metallic	0 537 33	
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Metallic	0 537 34	

Appliance Inlet						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63 A	2P+E	200/250 V~	50/60 Hz	6h	Plastic	0 537 72	0 593 76
63 A	3P+E	380/415 V~	50/60 Hz	6h	Plastic	0 537 73	0 594 77
63 A	3P+N+E	200/346 V~ 240/415 V~	50/60 Hz	6h	Plastic	0 537 74	0 594 78

Type of accessory	- Plugs - Connectors - Socket-outlet - Appliance inlets
Rated operating voltage:	2P+E : 200/250 V~ 3P+E: : 200/250 V~, 380/415 V~, 440/460 V~, 480/500 V~, 3P+N+E: 200/346 V~ to 240/415 V~,
Rated current:	63 A
Degree of protection:	IP44, IP55, IP66/67
Standard sheet:	2-IIIa, 2-IVa
Position of earthing contact:	6h, 7h, 9h
Keyway position:	without
Type of terminal:	screw-type
Plugs and connectors	
Type of cable exit:	straight - angled
Appliance inlet and socket-outlet	
Type of installation:	panel type – surface-type



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 24/04/2017

Signature: Jean-François BRUEL
Certification Officer