



中国国家强制性产品认证证书

证书编号：2014010307687754

委托人名称、地址

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

生产者（制造商）名称、地址

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

生产企业名称、地址

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

产品名称和系列、规格、型号

家用和类似用途的带过电流保护的剩余电流动作断路器

410792, 410793, 410794, 410795, 410796 411185, 411186, 411187, 411188, 411189 411233, 411234, 411235, 411236, 411237: Ue: 1P+N: AC230V; 4P: AC400V; Uimp: 4kV; Ui: 1P+N: AC250V; 4P: AC500V; In: 10A, 16A, 20A, 25A, 32A; 瞬时脱扣类型: C 型; Ics: 6kA; Icn: 6kA; IΔn: 30mA; 额定剩余动作类型: A 型, AC 型; 额定剩余动作类型: 电磁式; IΔm: 1P+N: 3kA; 4P: 4.5kA; 极数: 1P+N(N 极可开闭), 4P; 适用于隔离; 型号解释见附件

产品标准和技术要求

GB/T16917. 1-2014; GB/T16917. 21-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2018 年 12 月 04 日 有效期至：2023 年 12 月 04 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2014 年 05 月 09 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010307687754

NAME AND ADDRESS OF THE APPLICANT

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

NAME AND ADDRESS OF THE MANUFACTURER

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

NAME AND ADDRESS OF THE FACTORY

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Residual current operated circuit-breaker with integral overcurrent protection

410792, 410793, 410794, 410795, 410796 411185, 411186, 411187, 411188, 411189 411233, 411234, 411235, 411236, 411237; Ue: 1P+N: AC230V; 4P: AC400V; Uimp:4kV; Ui: 1P+N: AC250V; 4P: AC500V; In: 10A, 16A, 20A, 25A, 32A; Type C; Ics: 6kA; Icn: 6kA; IΔn: 30mA; Type A, Type ACElectromagnetic; Residual Current Trip Unit; IΔm: 1P+N: 3kA; 4P: 4.5kA; Poles: 1P+N(N switched N pole), 4P; Suitable for isolation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014;GB/T16917.21-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.04,2018

Valid until: Dec.04,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.09,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2014010307687754

纸 号: 2110210

型号解释:

410792---1P+N, In=10A, IΔn:30mA, AC 型, Ue=230V,	410793---1P+N, In=16A, IΔn:30mA/AC 型, Ue=230V,
410794---1P+N, In=20A, IΔn:30mA/AC 型, Ue=230V,	410795---1P+N, In=25A, IΔn:30mA/AC 型, Ue=230V,
410796---1P+N, In=32A, IΔn:30mA/AC 型, Ue=230V,	411185---4P, In=10A, IΔn:30mA/AC 型, Ue=400V,
411186---4P, In=16A, IΔn:30mA/AC 型, Ue=400V,	411187---4P, In=20A, IΔn:30mA/AC 型, Ue=400V,
411188---4P, In=25A, IΔn:30mA/AC 型, Ue=400V,	411189---4P, In=32A, IΔn:30mA/AC 型, Ue=400V,
411233---4P, In=10A, IΔn:30mA/A 型, Ue=400V,	411234---4P, In=16A, IΔn:30mA/A 型, Ue=400V,
411235---4P, In=20A, IΔn:30mA/A 型, Ue=400V,	411236---4P, In=25A, IΔn:30mA/A 型, Ue=400V,
411237---4P, In=32A, IΔn:30mA/A 型, Ue=400V	

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心