

CERTIFICATE

Issued to:
Applicant:
Legrand Nederland B.V.
Van Salmstraat 76
5281 RS Boxtel, The Netherlands

Manufacturer/Licensee:
Legrand France
128, av. du Maréchal-de-Lattre
87045 Limoges Cedex, France

Product(s) : terminal blocks
Trade name(s) : LEGRAND
Type(s)/model(s) : NS

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60998-2-1:2004;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 25 April 2014 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2171325.02

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: terminal blocks
trade name(s)	: LEGRAND
type(s)	: NS10, NS16, NS25, NS4, NS6
rated insulation voltage	: 250 V
temperature rating	: 55 °C
degree of protection	: IP00
material	: thermoplastic material
colours	: see product data per type
description	: terminal blocks with screw-type terminals, 12-poles
markings	: tradename, type designation and complete electrical rating are visible in the thermoplastic material

Product data - type NS4

rated connection capacity	: 2,5 mm ²
connectable conductors	: 1 mm ² - 2,5 mm ² flexible 1 mm ² - 2,5 mm ² rigid
colours	: black, grey, white

Product data - type NS6

rated connection capacity	: 6 mm ²
connectable conductors	: 1,5 mm ² - 4 mm ² flexible 1,5 mm ² - 6 mm ² rigid
colours	: black, grey, white, blue, green

Product data - type NS10

rated connection capacity	: 10 mm ²
connectable conductors	: 4 mm ² - 6 mm ² flexible 4 mm ² - 10 mm ² rigid
colours	: black, grey, white, blue, purple

Product data - type NS16

rated connection capacity	: 16 mm ²
connectable conductors	: 6 mm ² - 10 mm ² flexible 6 mm ² - 16 mm ² rigid
colours	: black, grey, white, blue, purple

Product data - type NS25

rated connection capacity	: 25 mm ²
connectable conductors	: 10 mm ² - 16 mm ² flexible 10 mm ² - 25 mm ² rigid
colours	: black, white, blue

TESTS

Test requirements
EN 60998-2-1:2004

Test results

The test results are laid down in DEKRA test file 2171325.02 and are based on CCA-FR 569628B and TRF No. 80562-569551.

Remarks

This certificate replaces certificate 2122747.01 (dated 31 August 2010).


Conclusion

The examination proved that all test requirements were met.

Tested by : M.T.H.van Gemen

A blue ink signature of M.T.H.van Gemen, consisting of several fluid, overlapping strokes.

Checked by : H.L. Schendstok

A blue ink signature of H.L. Schendstok, featuring a large, circular, scribbled signature.**Factory locations**

Legrand France
Rue Paul Nouel, 76770, Malaunay
France