

his certificate applies only to the apparatus tested. The

sponsibility for conformity of any apparatus having the same designation with that

manufacturer or responsible

This certificate has been

(Low Voltage Agreement Group) Objectives and

epared according to LOVAG

perating Principles of mutual

The responsible certification body as member of LOVAG

Conformity with the above mentioned Standard(s) following the exclusive use of

LOVAG Test Instructions

Only integral reproduction of

reproductions of this page accompanied by any page(s)

on which are stated the tests

performed and the assigned rated characteristics of the

apparatus Tested, are

permitted without written

ission from the LOVAG ory responsible for this

Certificate.

of this certificate CAE certification scheme.

wherever applicable.

this Certificate or

issues a Certificate of

tested rests with the

vendor

recognition.

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

ia Tito Livio, 5 – 24123 – BERGAMO (Italy) el. +390354175244 fax. +390354534662 e-mail:acaecert@tin.it



## **Certificate** of Conformity

LOVAG-Certificate No. IT 12.016

**Apparatus** 

Four pole fixed circuit breaker with elettromagnetic overcurrent releases -  $400 \text{ V} (U_e)$  -  $500 \text{ V} (U_i)$  -  $125 \text{ A} (I_{th}/I_{the})$  -  $50/60 \text{ Hz} - I_{cu} 16 \text{ kA}$  at  $400 \text{ V} - I_{s} 12 \text{ kA}$  at  $400 \text{ V} - I_{n} = 125 \text{ A}$ 

Designation

DX<sup>3</sup> 10/16 kA (type D125)

Manufacturer or responsible vendor

**Legrand S.n.c.** -128, Av.du Maréchal-de-Lattre-de-Tassigny-87045 Limoges Cedex (France)

Tested for: Legrand S.n.c.

Tested by: ACAE Laboratory IB01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 60947-2 (2009-05) Ed.4.1 – EN 60947-2:2006 + A1 (2009).

Test sequence: I

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below.

Suitable for isolation Utilization category A

 $400 \text{ V} (U_e) - 50/60 \text{ Hz}$ 

- Tripping limits according to the declared time/current characteristics
- Dielectric properties:
- Insulation voltage 500 V
- Impulse withstand voltage 4 kV
- Operation cycles:
- without current: 7000
- with current: 1000
- Rated thermal current: 125 A

This document includes: Test Report No.: 10.197-1

Issue date: 2012.02.13

L'ENTE ITALIANO DI ACCREDITAMENTO

PRD N°070B Signatory of EA, IAF and ILAC Mutual Recognition Agreements Responsible Certification Body: ACAE

Mauro Marchi

Authorized signature

Date: 2012.04.04

