SL

making connections beautifully

Wiring Accessories • Circuit Protection • Smart Lighting Control & Multi-room Audio **INWH-R** Grid-IT Neon Halo Module White/Red Item Image Wiring **Dimensions** 50V~ ONLY GRID-IT Primary Range Insert Type Neon Halo Module Plate Finish GRID-IT Module No Plate Colour Insert Colour White/Red EAN13 Barcode 5051164159412 Weight 18 GR Switched Poles N/A **Current Rating** N/A Voltage 220/250V AC Maximum Load N/A IP2XD IP Rating Contact Gap Minimum N/A Terminal Capacity 1 5 x 1mm2 Terminal Capacity 2 4 x 1.5mm2 Terminal Capacity 3 2 x 2.5mm2 Terminal Capacity 4 2 x 4mm2 Multi-strand **Terminal Capacity 5** 1 x 6mm2 Earth Terminal Capacity 1 6 x 1mm2 Earth Terminal Capacity 2 5 x 1.5mm2 Earth Terminal Capacity 3 3 x 2.5mm2 Earth Terminal Capacity 4 2 x 4mm2 Multi-strand Earth Terminal Capacity 5 1 x 6mm2 Product Class 1 Face plate must be earthed Ambient Operating Temperature -5° to +40°C Internal Use Only Recommended Location Maximum Installation Altitude 2000m Standard/Approval BS 5733 Module Size Height = 51mm Width = 23mm Depth = 20mm All accessories are manufactured under an accredited BS EN ISO 9001 : 2015 Quality Management System. All products listed conform to current British or It is the policy of the company to improve products European standard and the product information is as part of our development programme correct at the time of going to press. Therefore, we reserve the right to alter designs and dimensions without prior notice Illustrations and diagrams are reproduced within the limitations of reproduction and printing Correct as at 15 October 2018 09:55 AM Due to manufacturing processes we cannot guarantee an exact colour match and shadings of

of certain finishes.

R Hamilton & Co Ltd, Unit 10 Carrick Business Centre, 4-5 Bonville Road, Brislington, Bristol, BS4 5NZ : +44 (0)1747 860088 F: +44 (0)1179 710414 :: info@hamilton-litestat.com www.hamilton-litestat.com Registered Office 1 Rushmills, Bedford Road, Northampton NN4 7YB Registered in London No. 941624 VAT Registration No. 222 6607 84











E&OE

process and are not binding