

# Powerpact 4 panelboards Bottom entry moulded case circuit breakers



## Incoming devices

Current rating	Number of poles	Style of board	Part number
----------------	-----------------	----------------	-------------

### Circuit breaker

100	3	A,C,D	<b>MGP1003X</b>
160	3	A,C,D	<b>MGP1603X</b>
250	3	A,C,D	<b>MGP2503X</b>
400	3	D	<b>MGP4003X</b>
630	3	D	<b>MGP6303X</b>
800	3	E	<b>33552 + LV433638 + 33646</b>
1250	3	G	<b>33564</b>
1600	3	G	<b>33568</b>

100	4	A,C,D	<b>MGP1004X</b>
160	4	A,C,D	<b>MGP1604X</b>
250	4	A,C,D	<b>MGP2504X</b>
400	4	D	<b>MGP4004X</b>
630	4	D	<b>MGP6304X</b>
800	4	E	<b>33555 + LV433639 + 33646</b>
1250	4	G	<b>33566</b>
1600	4	G	<b>33570</b>

If specifying alternative breakers for the 800A panelboard, one long terminal shield and one set of phase separators must also be ordered.

### Switch disconnecter

100	3	A,C,D	<b>MGP1003NAX</b>
160	3	A,C,D	<b>MGP1603NAX</b>
250	3	A,C,D	<b>MGP2503NAX</b>
400	3	D	<b>MGP4003NAX</b>
630	3	D	<b>MGP6303NAX</b>
800	3	E	<b>33487 + LV433638 + 33646</b>
1250	3	G	<b>33489</b>
1600	3	G	<b>33490</b>

100	4	A,C,D	<b>MGP1004NAX</b>
160	4	A,C,D	<b>MGP1604NAX</b>
250	4	A,C,D	<b>MGP2504NAX</b>
400	4	D	<b>MGP4004NAX</b>
630	4	D	<b>MGP6304NAX</b>
800	4	E	<b>33492 + LV433639 + 33646</b>
1250	4	G	<b>33494</b>
1600	4	G	<b>33495</b>

### Direct connection

250	3	C	<b>MGP2503LL</b>
250	4	C	<b>MGP2504LL</b>
630	4	D	<b>MGPCIN</b>

Protection must be provided upstream by a suitably rated breaker.

### Disconnectable neutral link

250	1	A,C,D	<b>MGP250NL</b>
630	1	D	<b>MGP630NL</b>