

Powerpact 4 panelboards
Top entry
moulded case circuit breakers

Incoming devices			
Current rating	Number of poles	Style of board	Part number
Circuit breaker			
100	3	C	MGP1003X
160	3	C	MGP1603X
250	3	C	MGP2503X
100	3	D	MGP1003TX
160	3	D	MGP1603TX
250	3	D	MGP2503TX
400	3	D	MGP4003TX
630	3	D	MGP6303TX
800	3	E	33552 + LV433638 + 33646
1250	3	G	33564
1600	3	G	33568
100	4	C	MGP1004X
160	4	C	MGP1604X
250	4	C	MGP2504X
100	4	D	MGP1004TX
160	4	D	MGP1604TX
250	4	D	MGP2504TX
400	4	D	MGP4004TX
630	4	D	MGP6304TX
800	4	E	33555 + LV433639 + 33646
1250	4	G	33566
1600	4	G	33570
If specifying alternative breakers for the 800A panelboard, one long terminal shield and one set of phase separators must also be ordered.			
Switch disconnecter			
100	3	C	MGP1003NAX
160	3	C	MGP1603NAX
250	3	C	MGP2503NAX
100	3	D	
160	3	D	
250	3	D	MGP2503NATX
400	3	D	MGP4003NATX
630	3	D	MGP6303NATX
800	3	E	33487 + LV433638 + 33646
1250	3	G	33489
1600	3	G	33490
100	4	C	MGP1004NAX
160	4	C	MGP1604NAX
250	4	C	MGP2504NAX
100	4	D	
160	4	D	
250	4	D	MGP2504NATX
400	4	D	MGP4004NATX
630	4	D	MGP6304NATX
800	4	E	33492 + LV433639 + 33646
1250	4	G	33494
1600	4	G	33495
If specifying alternative breakers for the 800A panelboard, one long terminal shield is required for the incoming terminals			
Direct connection			
250	3	C	MGP2503LL
250	4	C	MGP2504LL
630	4	D	MGPCIN
Protection must be provided upstream by a suitably rated breaker.			
Disconnectable neutral link			
250	1	C,D	MGP250NL
630	1	D	MGP630NL