

### Function

They remotely trip or indicate circuit breakers, with or without Vigi module.

### Description

- They are mounted to the left of the circuit-breaker within a maximum width of 54mm
- Fixed using clips (no tools) onto the left side of the circuit breaker

### Auxiliary combination

- A maximum of 3 indication auxiliaries OF, SD on the same circuit breaker
- A maximum of 2 changeover auxiliaries (OF+SD/OF) on the same circuit breaker
- A maximum of 1 OF+SD/OF switchover auxiliary and 1 indication auxiliary OF or SD on the same circuit breaker
- A maximum of 2 tripping auxiliaries (MX+OF, MX, MN, MNs, MNx) on the same circuit breaker
- A maximum of 3 tripping auxiliaries MSU on the same circuit breaker without other auxiliary

