

## 55400-894APO

AlarmSense Manual Call Point surface



### Overview

Certified to EN54 Part 11 (LPCB).

Supplied with a non-breaking plastic resettable element.

Suitable for use with C-TEC's CFP AlarmSense range of 2-8 Zone Two-Wire Fire Panels.

Includes test key and red back box.

Easy access, front reset mechanism.

Ergonomic reset key.

170° viewable LED.

Suitable for surface or semi-flush mounting.

### Technical Specifications

<b>Approvals/certifications</b>	Certified to EN54 Part 11 by the LPCB.
<b>Supply/operating voltage</b>	9 to 33V DC.
<b>Quiescent current</b>	50µA.



<b>Alarm current</b>	1.5mA @ 2-8.5V; 30 +/- 4mA @ 10.5-15V; 1.5AmA @ 18-24V; 2mA @ 33V.
<b>Product dimensions (mm)</b>	90 W x 90 H x D 63mm (includes back box). 30mm D without back box.
<b>Construction &amp; finish</b>	Red ABS. Plastic element.
<b>IP Rating</b>	IP44.
<b>Weight</b>	156g.
<b>Operating conditions/temperature</b>	-40°C to +70°C.



T 01942 322744 E sales@c-tec.co.uk  
F 01942 829867 W www.c-tec.com



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom



T 01942 322744 E [sales@c-tec.co.uk](mailto:sales@c-tec.co.uk)  
F 01942 829867 W [www.c-tec.com](http://www.c-tec.com)



C-TEC, Challenge Way, Martland Park, Wigan, WN5 0LD United Kingdom